

CERTIFICATE OF CONFORMITY

This Certificate is issued to

DELTA TECHNOLOGY PTE LTD
(UEN No.: 198900875K)
No. 34 Loyang Crescent, Singapore 508993

For Product Certification Scheme: Type 1b

Product : **Fire Rated Shutter**

Brand : **Delta Technology**

Model : **HFRS240**

Country of Origin : **Singapore**

Product Details : **An uninsulated single-screen horizontal sliding roller shutter.**
Maximum Clear Opening Size: 7m (W) x 40m (L)
Integrity: 240 mins
Refer to Appendix for more details.

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

EN 1634-1: 2014 + A1: 2018

TEST REPORT(S)

RED Test Report No.: R24D50-1A

RED Letter Reference No.: R24D50-1A_s2

RED Assessment Report No.: R24E29-1A Issue 1

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



Fiona Leong (Ms)
Program Manager
SETSCO Services Pte Ltd

Certificate No

FSP-2024-1594

Date of Issue

22/08/2024

Date of Expiry

21/08/2029

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10