



CERTIFICATE OF CONFORMITY

This Certificate is issued to

DELTA TECHNOLOGY PTE LTD

(UEN No.: 198900875K)

No. 34 Loyang Crescent, Singapore 508993

For Product Certification Scheme: Type 1b

Product

: Fire Rated Shutter

Brand

Delta Technology

Model

FRS240

Country of Origin

Singapore

Product Details

: An uninsulated single screen vertical sliding roller

shutter.

Maximum Size: 14m (width) x 9m (height)

Integrity: 240 mins

Refer to Appendix for more details.

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

TEST REPORT(S)

EN 1634-1: 2014 + A1: 2018

RED Test Report No.: R22A23-1A

RED Assessment Report No.: R23L22-1A

Detailed configuration and installation shall be referenced to the certified report(s) stated above.

Fiona Leong (Ms)

Program Manager SETSCO Services Pte Ltd 531 Bukit Batok Street 23, Singapore 659547

Certificate No

Date of Issue

Date of Last Revision

Date of Expiry

FSP-2023-1324

24/02/2023

25/01/2024

23/02/2028

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.