

CERTIFICATE OF CONFORMITY

This Certificate is issued to

DELTA TECHNOLOGY PTE LTD
No. 34 Loyang Crescent
Singapore 508993

For Product Certification Scheme: Type 1b

Product : **Fire Rated Shutter**
Brand : **SBS**
Model : **FR3286**
Country of Origin : **Singapore**
Product Details : **An un-insulated single-screen vertical sliding roller shutter**
Overall shutter size: 14m (W) x 9m (H)
Integrity: 240 mins

which has complied with the requirements of the scheme based on the following:

STANDARD(S)	TEST REPORT(S)
BS EN 1634-1: 2008	REDTest Report No.: R17M29-1A RED Assessment Report No.: R181310-1A



Sze Thiam Siong (Mr)
General Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No
FSP-2015-0298

Date of Issue
24/12/2018

Date of Expiry
23/12/2023



This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is governed by SETSCO's Terms and Conditions for Certification. The certified client is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking SETSCO website at www.setsco.com