

CERTIFICATE OF CONFORMITY

This Certificate is issued to

DELTA TECHNOLOGY PTE LTD
No. 34 Loyang Crescent
Singapore 508993

For Product Certification Scheme: Type 1b

Product : **Fire Rated Shutter**

Brand : **Delta Technology**

Model : **IFSS-240**

Country of Origin : **Singapore**

Product Details : **A fully insulated vertical sliding roller shutter.**
Shutter Dimension: 14m (W) x 7.5m (H)
Integrity: 240 mins; Insulation: 240 mins
Refer to Appendix for details.

which has complied with the requirements of the scheme based on the following:

STANDARD(S)	TEST REPORT(S)
EN 1634-1: 2014	RED Test Report No.: R19J08-2A RED Assessment Report No.: R19L13-1A



Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No
FSP-2020-0940

Date of Issue
19/02/2020

Date of Expiry
18/02/2025

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.